

FIRE FREE ENGINEER'S

FIRE PROTECTION ENGINEERS & GOVT. CONTRACTORS

Authorised Distributor :-

JAINEX (FIRE & SAFETY) SYSTEM PVT. LTD. MUMBAI



2253649

Beside Maharashtra Bhawan,

Choubey Colony,

RAIPUR - 492 001(C.G.)

Mobile : 94252-11527

TEST CERTIFICATE/INSPECTION CERTIFICATE

Customer's Name & Address :

Gyan Ganga Educational
Academy Vidhan Sabha
Road Nardaha Raipur (C.G.)

Dated :- 08/06/23
Next Refill :- 07/06/24

This is to Certify that Mr. R. S. Sahu has made the
periodical inspection/Testing of the fire Extinguishers installed here.

1. Present installation of Fire Extinguishers 05 NOS 02kg Capacity ABC Type
03 NOS ABC Type 01kg Capacity A/E + 02 NOS 04kg Capacity
ABC Type + 02 NOS 06kg Capacity ABC Type + 05 NOS 05kg
2. No. of Refills in hand and condition Capacity DCB Type fire Extinguishers
3. Fire Extinguishers for Hydraulic test All fire Extinguishers operated tested and
Refilled found ok
4. Extinguishers failed during Hydraulic test N/A
5. Any new Fire Extinguishers/Refills required N/A
6. State person (s) present at the time of inspection / Resting ① Mohit ② Jeewan
7. Have the Fire Extinguishers being used at any outbreak of fire since last inspection
Note :- fire Extinguishers Dummy Demonstrated

Seal

Customer's Singnature

For, FIRE FREE ENGINEER'S

